

# Compliance Statement

No. 2023-550

## Unscreened Channel, Class E

### Company

FibreFab Limited / AFL HYPERSCALE  
Knowlhill  
MK5 8HJ  
Milton Keynes, Buckinghamshire  
United Kingdom

### Channel Identification (3 connector model)

#### Horizontal cable:

Unscreened Category 6 cable  
Part no. UUTP6305xxxx, UUTP6500xxxx, UCC411xxx (x: jacket colour and material)

#### RJ45 connector for telecommunications outlet:

Unscreened Category 6 connector  
Part no. 600-1xx, UCT214xxx (x: colour and termination type)

#### Patch panel:

Unscreened Category 6 patch panel  
Part no. 600-003, UPP21141x (x: panel height)

#### Terminal cord, patch cords:

Unscreened Category 6 patch cord  
Part no. 611-xyy, UPC4115xxx300y (x: jacket colour and material, y: length)

#### Equipment cord:

Unscreened Category 6 patch cord (terminated in patch panel)  
Part no. 621-xx3, UPC4115xxx3003 (x: jacket colour and material)

### Generic cabling standards - Class E Channel requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018

### Technical report

12326878-01, DANAK-19/23652

### EC Cabling product ID


6712

### CS valid until

1 September 2024

This product has been tested by FORCE Technology up and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 6 September 2023



Lars Lindskov Pedersen  
Test Manager



Dennis Andersen  
Head of Department

