Attestation of Conformity

No. 2017-357A

Cables for use in construction works
Reaction to fire class D_{ca}

Company
Alcadon AB
Segelbåtsvägen 7
112 64 Stockholm
Sweden

Product description
Unscreened communication cable (U/UTP) with solid conductors
4 twisted pairs, LSZH

Product identification
U/UTP Cat. 6 LSZH
Part no. UTP6NG, BBK6U, UTP6L, 131733, OC1001

Reaction to fire standards
- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 50399:2011 including amendment A1:2016
- EN 60754-2:2014 including amendment A1:2020
- EN 13501-6:2018

Reaction to fire classification
Class D_{ca}-s2,d2,a1

Technical report
T726915, DANAK-19/17690

EC Cabling product ID
6261

This product has undergone a one-time test performed by FORCE Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.
This Attestation of Conformity has been revised, original issue date 19 April 2017.

Hørsholm, 6 January 2023

Lars Lindskov Pedersen
Test Manager

Dennis Andersen
Head of Department

FORCE Technology
Venlighedsvej 4
2970 Hørsholm
Denmark
Tel. +45 43 25 14 00
lan.forcetechnology.com