# Attestation of Conformity

**No. 2017-941A**

## Cables for use in construction works
## Reaction to fire class $D_{ca}$

**Company**
Alcadon AB
Segelbåtsvägen 7
112 64 Stockholm
Sweden

**Product description**
Screened communication cable (F/FTP) with solid conductors
4 twisted pairs, LSZH

**Product identification**
F/FTP Cat. 6A LSZH
Part no. STP6A-NG, OC3001

**Reaction to fire standards**
- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 50399:2011 including amendment A1:2016
- EN 60754-2:2014 including amendment A1:2020
- EN 13501-6:2018

**Reaction to fire classification**
Class $D_{ca}$-s1,d1,a1

**Technical report**
T736256, DANAK-19/18573

**EC Cabling product ID**
6528

This product has undergone a one-time test performed by FORCE Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.
This Attestation of Conformity has been revised, original issue date 16 November 2017.

Hørsholm, 6 January 2023

Lars Lindskov Pedersen
Test Manager

Dennis Andersen
Head of Department

**FORCE Technology**
Venlighedsvej 4
2970 Hørsholm
Denmark
Tel. +45 43 25 14 00
lan.forcetechnology.com