Attestation of Conformity

No. 2022-810

Cables for use in construction works
Reaction to fire class D_{ca}

Company
Alcadon AB
Segelbåtsvägen 7
112 64 Stockholm
Sweden

Product description
Unscreened communication cable (U/UTP) with solid conductors
4 twisted pairs, LSZH

Product identification
U/UTP Cat. 6A LSZH
Part no. OC2001

Reaction to fire standards
- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 50399:2011 including amendment A1:2016
- EN 60754-2:2014 including amendment A1:2020
- EN 13501-6:2018

Reaction to fire classification
Class D_{ca}-s2,d2,a1

Technical report
12234321-02, DANAK-19/23134

EC Cabling product ID
7444

This product has undergone a one-time test performed by FORCE Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

Hørsholm, 15 December 2022

Lars Lindskov Pedersen
Test Manager

Dennis Andersen
Head of Department

FORCE Technology
Venlighedsvej 4
2970 Hørsholm
Denmark
Tel. +45 43 25 14 00
lan.forcetechnology.com