

Attestation of Conformity

No. 2019-744

Cables for use in construction works Reaction to fire class D_{ca}

Company

Atlas (Scotland) Ltd.
Unit 5 block 8, Moorfield Industrial Estate
Troon Road
KA2 OBA Kilmarnock
Scotland
United Kingdom

Product description

Screened communication cable (S/FTP) with solid conductors
4 twisted pairs, LSZH jacket

Product identification

S/FTP Cat. 7 LSZH
Part no. CABLE-01051/0

Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 50399:2011 including amendment A1:2016
- EN 60754-2:2014
- EN 13501-6:2018

Reaction to fire classification

Class D_{ca}-s1,d2,a1

Technical report


T934369-02, DANAK-19/20678

EC Cabling product ID

7000

This product has undergone a one-time test performed by FORCE Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

Hørsholm, 28 October 2019



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department