

# Compliance Statement

No. 2023-699

## Unscreened Channel, Class E

### Company

Bimel Elektronik Mam. Paz. A. S.  
Bayindir Sok. 5/4-7 Yenisehir  
06420 Ankara  
Turkey

### Channel Identification (4 connector model)

#### Horizontal cable:

Beek Cat6 U/UTP Horizontal LSOH Cable  
Part no. BC-XXX-UU6-HF (XXX coding for length)

#### RJ45 connector for telecommunications outlet, consolidation point, and patch panel:

Beek Cat6 Unshielded Toolless Keystone  
Part no. BN-KJ6-U1

#### Terminal cord, patch cord:

Beek Cat6 U/UTP LSOH Patch Cord  
Part no. BC-U6XXX (XXX coding for length, Y coding for colour)

#### Consolidation point cord, equipment cord:

Beek Cat6 U/UTP LSOH Cons. P. Cord  
- with jack BN-KJ6-U1 added  
Part no. BC-U6XXX-CP (XXX coding for length, Y coding for colour)

#### Generic cabling standards - Class E Channel requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018

#### Technical report

12334202-01, DANAK-19/23842

#### EC Cabling product ID


7294

#### CS valid until

1 December 2024

This product has been tested by FORCE Technology up and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 13 November 2023



Lars Lindskov Pedersen  
Test Manager



Dennis Andersen  
Head of Department