

Attestation of Conformity

No. 2017-962A

Cables for use in construction works Reaction to fire class D_{ca}

Company

British Cables Company Ltd
Delaunays Road, Blackley
Manchester, M98FP
United Kingdom

Product description

Screened communication cable (F/UTP) with solid conductors
4 twisted pairs, LSZH

Product identification

BCC Data-Tec™ Cat 6 FUTP LSZH
Part no. BTXCMD4600Z07

Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 50399:2011 including amendment A1:2016
- EN 13501-6:2018

Reaction to fire classification

Class D_{ca}-s2,d1

Technical report

T736220-03, rev. 1, DANAK-19/18609


EC Cabling product ID

6544

This product has undergone a one-time test performed by FORCE Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

This Attestation of Conformity has been revised, original issue date 5 December 2017.

Hørsholm, 10 December 2020



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department