

# Compliance Statement

No. 2022-720

## Data communication cable, Category 7A

### Company

Caleb Cable Industrial Ltd.  
Rm 2102, Landmark North  
39 Lung Sum Avenue  
Sheung Shui, N.T.  
Hong Kong

### Product description

Screened cable (S/FTP) characterised up to 1200 MHz\*  
Horizontal floor wiring cable, 100  $\Omega$   
4 and 2x4 individually foil screened twisted pairs with overall braid screen  
Flame retardant, halogen free

### Product identification

S/FTP Cat 7A, LSZH 1200 MHz  
S/FTP Cat 7A, LSZH 1200 MHz, dual

### Generic cabling and cabling components standards - Category 7A cable requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- IEC 61156-5:2020 (Ed. 3.0)
- EN 50173-1:2018 / EN 50173-2:2018
- EN 50288-9-1:2012

### Standards for flammability, halogen acidity, and smoke performance

- IEC 60332-1-1:2015 (Ed. 1.1) / IEC 60332-1-2:2015 (Ed. 1.1)
- IEC 60754-2:2019 (Ed. 2.1)
- IEC 61034-1:2019 (Ed. 3.2) / IEC 61034-2:2019 (Ed. 3.2)

### Technical report

12231170-04, DANAK-19/23049  
12231170-05, DANAK-19/23050

### EC Cabling product ID

5228  
6071


### CS valid until

1 August 2023

\*Transmission parameters comply with IEC 61156-7 and with extended Cat. 7A limits up to 1200 MHz.

This product has been tested by FORCE Technology and complies with the requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance schedule, which implies that FORCE Technology performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis.

Hørsholm, 17 November 2022

  
Lars Lindskov Pedersen  
Test Manager

  
Dennis Andersen  
Head of Department