

Compliance Statement

No. 2026-137

Screened Channel, Class E_A

Company

CobiCabling Sp. z o.o.
Austriacka 4
64-100 Leszno
Poland

Channel Identification (4 connector model)

Horizontal cable:

CobiCabling Solid Cable cat. 6A/7 F/FTP 700MHz LSFROH B2ca; Part no. C23-1520

RJ45 connector for telecommunications outlet, consolidation point, and patch panel:

CobiCabling Keystone jack cat. 6A STP toolless; Part no. C21-1001 (for patch panel)

CobiCabling Angled Keystone jack cat. 6A STP toolless; Part no: C21-1002 (CP)

CobiCabling cat. 6A STP RJ45-RJ45 connector; Part no. C26-1421 (TO)

Terminal cord, consolidation point cord:

CobiCabling Patch cord cat. 6A S/FTP 26AWG 5M; Part no. C24-11xx-5,0

Patch cord:

CobiCabling Patch cord cat. 6A S/FTP 26AWG 2M; Part no. C24-11xx-2,0
(with jack C21-1001 added for patch panel)

Equipment cord:

CobiCabling Patch cord cat. 6A S/FTP 26AWG 3M; Part no. C24-11xx-3,0

Generic cabling standards - Class E_A Channel requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-E:2024

Technical report

12620802-01, DANAK-19/25503

EC Cabling product ID

8218

CS valid until


1 May 2027

This product has been tested by FORCE Technology up and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 10 February 2026



Nis Jepsen
Specialist, Project Manager



Lars Lindskov Pedersen
Senior Team Leader, Test Manager

