

## Certificate of constancy of performance

Regulation for Construction Products

Certificate No.: 0200-CPR-10352 version 01

Issued by FORCE Certification A/S - EC-notified body number 0200

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

### Power, control and communication cables

Product	Intended use	Class	AVCP system
U/UTP Cat. 6 LSZH dual Part no.: C6UHR2X4FR-TP037A	Supply of electricity and communication inside buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke	C <sub>ca</sub> -s1a,d1,a1	1+

placed on the market under the name or trade mark of:

**CONNECTIS / GIGAMEDIA**  
**CRT n°4, 312 Rue des Hauts de Sainghin**  
**59811 Lesquin**  
**France**

and produced in the manufacturing plant(s):

**CONNECTIS / GIGAMEDIA**  
**Manufacturing plant A**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the Annex ZZ of the standard:

**EN 50575:2014 + A1:2016**

under system 1+ for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 2021-02-22 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods, nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by FORCE Certification A/S.

FORCE Certification A/S task No.: 121-23356. Certificate ID No.: 10352.

Date of issue: 2021-02-22  
Date of expiry: 2024-02-22



Dennis Andersen  
Certification manager

Extracts from this Product Certificate may only be reproduced with a written permission from FORCE Certification A/S