

Attestation of Conformity

No. 2019-389

Cables for use in construction works Reaction to fire class D_{ca}

Company

CONNECTIS / GIGAMEDIA
CRT No. 4 Rue des Hauts de Sainghin
59811 Lesquin Cedex
France

Product description

Unscreened communication cable (U/UTP) with solid conductors
4 twisted pairs, LSZH jacket

Product identification

U/UTP CAT.6 24AWG LSZH
Part no. C6U4PDCA-TP023B

Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 50399:2011 including amendment A1:2016
- EN 60754-2:2014
- EN 13501-6:2014

Reaction to fire classification

Class D_{ca}-s2,d2,a1

Technical report


T928963-01, DANAK-19/20244

EC Cabling product ID

6920

This product has undergone a one-time test performed by FORCE Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

Hørsholm, 20 June 2019



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department