

# Compliance Statement

No. 2023-713

## Data communication cable, Category 6

### Company

Corning Optical Communications GmbH & Co. KG  
Profilstr. 4  
58093 Hagen  
Germany

### Product description

Screened cable (F/UTP) characterised up to 250 MHz  
Horizontal floor wiring cable, 100 Ω  
4 twisted pairs with overall foil screen  
Flame retardant, halogen free

### Product identification

VOL6FL4xx F/UTP AWG 24, Cat.6, LSOH, CPR Dca  
Catalog numbers:  
FQ100003216  
XE004802288

### Generic cabling and cabling components standards - Category 6 cable requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- IEC 61156-5:2020 (Ed. 3.0)
- EN 50173-1:2018 / EN 50173-2:2018
- EN 50288-5-1:2013
- TIA-568.2-D:2018

### Standards for flammability, halogen acidity, and smoke performance

- IEC 60332-1-1:2015 (Ed. 1.1) / IEC 60332-1-2:2015 (Ed. 1.1)
- IEC 60754-2:2019 (Ed. 2.1)
- IEC 61034-1:2019 (Ed. 3.2) / IEC 61034-2:2019 (Ed. 3.2)

### Technical report

12334461-01, DANAK-19/23858

### EC Cabling product ID


5173

### CS valid until

1 December 2024

This product has been tested by FORCE Technology and complies with the requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance schedule, which implies that FORCE Technology performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis.

Hørsholm, 21 November 2023

  
Lars Lindskov Pedersen  
Test Manager

  
Dennis Andersen  
Head of Department