

Attestation of Conformity

No. 2020-185A

Cables for use in construction works Reaction to fire class D_{ca}

Company

Corning Optical Communications GmbH & Co. KG
Leipziger Str. 121
10117 Berlin
Germany

Product description

Screened communication cable (U/FTP) with solid conductors
4 twisted pairs, LSZH

Product identification

CCXERA-B0047-C001-XX (U/FTP_T): U/FTP 250/23,4P,Cat.6,LSOH,\$\$,CPR D
(XX: length; \$\$: colour)

Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 50399:2011 including amendment A1:2016
- EN 60754-2:2014
- EN 13501-6:2018

Reaction to fire classification

Class D_{ca}-s1,d1,a1

Technical report


12023436-03, DANAK-19/20966

EC Cabling product ID

7067

This product has undergone a one-time test performed by FORCE Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.
This Attestation of Conformity has been revised.

Hørsholm, 20 February 2020



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department