

Attestation of Conformity

No. 2020-183

Cables for use in construction works Reaction to fire class E_{ca}

Company

Corning Optical Communications GmbH & Co. KG
Leipziger Str. 121
10117 Berlin
Germany

Product description

Screened communication cable (F/UTP) with solid conductors
4 twisted pairs, PVC jacket

Product identification

VOL-6FP4 XX (F/UTP_P): VOL6FP4XX F/UTP24,4P,Cat.6,PVC,\$\$,CPR E
(XX: length; \$\$: colour)

Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 13501-6:2018

Reaction to fire classification

Class E_{ca}

Technical report


12023436-01, DANAK-19/20964

EC Cabling product ID

7065

This product has undergone a one-time test performed by FORCE Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

Hørsholm, 19 February 2020



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department