

# Compliance Statement

No. 2023-755

## Unscreened Permanent Link, Class E (with ground continuity)

### Company

Corning Optical Communications GmbH & Co. KG  
Profilstr. 4  
58093 Hagen  
Germany

### Permanent Link Identification (2 connector model)

#### Horizontal cable:

F/UTP 450/23 Cat.6, LSZH™/FRNC, 4P, Dca / CCXEDE-DD047-V000\$-## (\$=color, ##=length)

#### RJ45 connector for telecommunications outlet and patch panel:

E250 FTP OCK6Fx, E250Fx Jack, RJ45 Vol, Cat.6, (Unscreened connector with ground continuity)

#### Generic cabling standards - Class E Permanent Link requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018

#### Technical report

12331952-02, DANAK-19/23900

#### EC Cabling product ID


5595

#### CS valid until

1 February 2025

This product has been tested by FORCE Technology and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 21 December 2023



Lars Lindskov Pedersen  
Test Manager



Dennis Andersen  
Head of Department

