

Compliance Statement

No. 2023-757

Screened Permanent Link, Class E_A

Company

Corning Optical Communications GmbH & Co. KG
Profilstr. 4
58093 Hagen
Germany

Permanent Link Identification (3 connector model)

Horizontal cable:

F/UTP 550/23, Cat.6A, LSZH™/FRNC, Dca 4P / CCXADE-DD047-V000\$-## (\$=color, ##=length)
F/UTP 550/23, Cat.6A, LSZH™/FRNC, Dca 2x4P / CCXADE-DD047-V000\$-## (\$=color, ##=length)

RJ45 connector for telecommunications outlet, consolidation point, and patch panel:

E500 STP OCK6ASEx, E500S, RJ45 Vol, Cat.6A

Consolidation point cord:

Cat.6A Patch Cord S/FTP flex/26, 2xRJ45, 4P / CCAAGB-Gx002-Ayyy-C0
(with jack E500 STP OCK6ASEx, E500S, RJ45 Vol, Cat.6A added)

Generic cabling standards - Class E_A Permanent Link requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018

Technical report

12331952-04, DANAK-19/23902

EC Cabling product ID


5111

CS valid until

1 February 2025

This product has been tested by FORCE Technology and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 21 December 2023



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department

