

Compliance Statement

No. 2023-758

Screened Permanent Link, Class Ea

Company

Corning Optical Communications GmbH & Co. KG
Profilstr. 4
58093 Hagen
Germany

Permanent Link Identification (3 connector model)

Horizontal cable:

S/FTP 800/23, Cat.7, LSZH™/FRNC, 4P / VOL10FL4xxx
S/FTP 800/23, Cat.7, LSZH™/FRNC, 2x4P / VOL10FL8xxx

RJ45 connector for telecommunications outlet, consolidation point, and patch panel:

E500 STP OCK6ASEx, E500S, RJ45 Vol, Cat.6A

Consolidation point cord:

Cat.6A Patch Cord S/FTP flex/26, 2xRJ45, 4P / CCAAGB-Gx002-Ayyy-C0
(with jack E500 STP OCK6ASEx, E500S, RJ45 Vol, Cat.6A added)

Generic cabling standards - Class Ea Permanent Link requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018

Technical report

12331952-05, DANAK-19/23903

EC Cabling product ID


5110

CS valid until

1 February 2025

This product has been tested by FORCE Technology and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 21 December 2023



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department