# Compliance Statement

**No. 2026-403**

## Screened Channel, Class $E_A$

**Company**
DTECH CABLING SYSTEMS (UK) LIMITED
86-90 PAUL STREET
EC2A 4NE LONDON
UNITED KINGDOM

**Channel Identification (4 connector model)**

**Horizontal cable:**
DTECH AV-READY CAT 6A (C6A-XFTP-ZH-NXX)

**RJ45 connector for telecommunications outlet, consolidation point, and patch panel:**
DTECH 10XG TOOL-FREE SHIELDED KEYSTONE JACK (MC10G-TLF-STP)

**Terminal cord, patch cord:**
DTECH PATCHKIT SHIELDED PATCH CORD (CXG-PKFTP-NXX)

**Consolidation point cord, equipment cord:**
DTECH PATCHKIT SHIELDED PATCH CORD (CXG-PKFTP-NXX)
(with KEYSTONE JACK (MC10G-TLF-STP) added)

**Including use with:**
Wall Outlet: DTECH CAT6A SHIELDED WALL OUTLET (EM-C6AS-XX)
Patch Panel: DTECH CAT6A SHIELDED PATCH PANEL (PPC6A-STP-XX)

**Generic cabling standards - Class $E_A$ Channel requirements**
- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-E:2024

| **Technical report** | **EC Cabling product ID** | **CS valid until** |
|---|---|---|
| 12623725-02, DANAK-19/25622 | 7775 | 1 April 2027 |

This product has been tested by FORCE Technology up and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 12 March 2026

Nis Jepsen
Specialist, Project Manager

Lars Lindskov Pedersen
Senior Team Leader, Test Manager

**FORCE Technology**
Venlighedsvej 4
2970 Hørsholm
Denmark
Tel. +45 43 25 14 00
lan.forcetechnology.com