

Compliance Statement

No. 2024-221

Unscreened Channel, Class E

Company

GAESTOPAS S.L
Poligono Industrial Akarregi
Parcela No. 6
Hernani 20120
Spain

Channel Identification (4 connector model)

Horizontal cable:

Cat6 U/UTP Unscreened Lan Cable, Part no. C016N30.1-DW

RJ45 connector for telecommunications outlet, consolidation point, and patch panel:

Cat6 UTP Unscreened Keystone Jack, Part no. CK16N

Terminal cord, patch cord and equipment cord:

Cat6 U/UTP Unscreened Patch Cord, Part no. CL016NZ.XX, [XX-Meter, Z-Color]

Consolidation point cord:

Cat6 U/UTP Lan Cable, Part No.:C016N30.1-DW, With Cat6 UTP Keystone Jack, Part no. CK16N and Cat6 UTP Termination Plug Mounted, Part no. TPXX.U6

Generic cabling standards - Class E Channel requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018

Technical report

12423949, DANAK-19/24111

EC Cabling product ID


7460

CS valid until

1 February 2025

This product has been tested by FORCE Technology up and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 23 February 2024



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department

