

Compliance Statement

No. 2024-223

Screened Modular Plug Terminated Link, Class EA

Company

HellermannTyton Data Ltd.
Waterside House,
Edgar Mobbs Way
Northampton NN5 5JE
United Kingdom

Modular Plug Terminated Link Identification (3 connector model)

Horizontal cable:

HellermannTyton Cat.6A F/FTP solid core LSZH Horizontal Cable
Part no. CA19x (CA199 = Cca Jacket / CA198 = Dca Jacket)

RJ45 connector for interconnect, equipment outlet, consolidation point:

HTC Series Screened Cat.6A RJ45 Tool-Free Jack
Part no HTC-C6AS-KJxx (xx = Pack size)

RJ45 modular plug termination:

HTC Series Screened Cat.6A field termination RJ45 plug
Part no. HTC-C6AS-MPxx (xx = Pack size)

Consolidation point cord:

HTC Series Screened Category 6A CP Cord
Part no. HTC-C6AS-MP/MP-xx.xM (xx.x = Length)
- with plugs HTC-C6AS-MP

Generic cabling standards - Class EA Permanent Link requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018
- ISO/IEC TR 11801-10:2020 (Ed. 1.0)

Technical report

12331969-01, DANAK-19/24090

EC Cabling product ID


7292

CS valid until

1 January 2025

This product has been tested by FORCE Technology and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 26 February 2024



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department

