

# Attestation of Conformity

No. 2022-629

## Cables for use in construction works Reaction to fire class E<sub>ca</sub>

### Company

KABLEX-UKRAINE, LLC  
Mayakovsky Avenue, Building 68, Office 233  
02232 Kyiv  
Ukraine

### Product description

Power cables with extruded insulation and solid conductors, Class 1 (product family)

### Product identification

VVGng-LS-P product family

Product name: VVGng-LS-P  $n \times A$ ; Part no.: KUc13-3  $nA$   
( $n$ : number of conductors,  $A$ : conductor cross section)

The classification applies for cables within the product family for:

- outer dimensions 6.6 mm×4.3 mm to 14.5 mm×6.3 mm
- conductor size 1.0 mm<sup>2</sup> to 6.0 mm<sup>2</sup>

### Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 13501-6:2018

### Reaction to fire classification

Class E<sub>ca</sub>

### Technical report


12223380-01, DANAK-19/22989

### EC Cabling product ID

7414

This product has undergone a one-time test performed by FORCE Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

Hørsholm, 13 October 2022



Lars Lindskov Pedersen  
Test Manager



Dennis Andersen  
Head of Department