

Attestation of Conformity

No. 2022-631

Cables for use in construction works Reaction to fire class E_{ca}

Company

KABLEX-UKRAINE, LLC
Mayakovsky Avenue, Building 68, Office 233
02232 Kyiv
Ukraine

Product description

Flexible low voltage cables with PVC insulation and stranded conductors, Class 5 (product family)

Product identification

SHVVPng-LS product family

Product name: SHVVPng-LS $n \times A$; Part no.: KUc41-3 nA
(n : number of conductors, A : conductor cross section)

The classification applies for cables within the product family for

- outer dimensions 5.06 mm×3.13 mm to 15.97 mm×6.39 mm
- conductor size 0.5 mm² to 6.0 mm²

Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 13501-6:2018

Reaction to fire classification

Class E_{ca}

Technical report


12223380-05, DANAK-19/22991

EC Cabling product ID

7416

This product has undergone a one-time test performed by FORCE Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

Hørsholm, 13 October 2022



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department