

Attestation of Conformity

No. 2022-661

Cables for use in construction works Reaction to fire class D_{ca}

Company

Lacson Co. Ltd
12F, No. 117, Xicheng Rd.,
Banqiao District,
NEW TAIPEI CITY 220
Taiwan R.O.C

Product description

Unscreened communication cable (U/UTP) with solid conductors
4 twisted pairs, LSZH jacket

Product identification

66504H-Dca CAT.6 U-UTP LSZH
Part no. 66504142xx-2 (xx: colour of jacket)

Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 50399:2011 including amendment A1:2016
- EN 60754-2:2014 including amendment A1:2020
- EN 13501-6:2018

Reaction to fire classification

Class D_{ca}-s2,d2,a1

Technical report


12232517-03, DANAK-19/ 23040

EC Cabling product ID

7425

This product has undergone a one-time test performed by FORCE Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

Hørsholm, 1 November 2022



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department