

# Attestation of Conformity

No. 2022-662

## Cables for use in construction works Reaction to fire class D<sub>ca</sub>

### Company

Lacson Co. Ltd  
12F, No. 117, Xicheng Rd.,  
Banqiao District,  
NEW TAIPEI CITY 220  
Taiwan R.O.C

### Product description

Screened communication cable (F/UTP) with solid conductors  
4 twisted pairs, LSZH jacket

### Product identification

66704H-Dca CAT.6 F-UTP LSZH  
Part no. 66704102xx-2 (xx: colour of jacket)

### Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 50399:2011 including amendment A1:2016
- EN 60754-2:2014 including amendment A1:2020
- EN 13501-6:2018

### Reaction to fire classification

Class D<sub>ca</sub>-s2,d2,a1

### Technical report


12232517-04, DANAK-19/ 23041

### EC Cabling product ID

7426

This product has undergone a one-time test performed by DELTA EC Cabling Group and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

Hørsholm, 1 November 2022



Lars Lindskov Pedersen  
Test Manager



Dennis Andersen  
Head of Department