Compliance Statement

No. 2026-236

Unscreened Permanent Link, Class E_A

Company
LANSYST OÜ
Liivametsa 6
Tallinn 11216
Estonia

Permanent Link Identification (2 connector model)

Horizontal Cable:
DNS Silver Link C6A U/UTP LSZH Dca: P/N 400120
DNS Silver Link C6A U/UTP LSZH B2ca; P/N 400160

RJ45 connector for telecommunications outlet and patch panel:
DNS CAT6A UTP Keystone T2; P/N 400812

Patch Panel:
DNS 24p UTP/STP panel staggered; P/N 400819

Generic cabling standards - Class E_A Permanent Link requirements
- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-E:2024

including all permanent link alien crosstalk parameters (PS ANEXT and PS AACR-F)

Technical report	**EC Cabling product ID**	**CS valid until**
12533423-02, DANAK-19/25495	5716	1 March 2027

This product has been tested by FORCE Technology and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 25 February 2026

Nis Jepsen
Specialist, Project Manager

Lars Lindskov Pedersen
Senior Team Leader, Test Manager

FORCE Technology
Venlighedsvej 4
2970 Hørsholm
Denmark
Tel. +45 43 25 14 00
lan.forcetechnology.com