Compliance Statement

No. 2026-612A

Data communication cable, Category 6_A

Company
LINK ASIA LIMITED
48 Floor 6 INTERLINK Building
Ratchadapisek Rd.
Samsennok, Huay Khwang
10310 Bangkok
Thailand

Product description
Screened cable (F/FTP) characterised up to 500 MHz
Horizontal floor wiring cable, 100 Ω
4 individually foil screened twisted pairs with overall foil screen
Flame retardant, halogen free

Product identification
LINK CAT 6A F/FTP, 23AWG, XG, Cable, LSZH PART NO. US-9267ALSZH

Generic cabling and cabling components standards - Category 6_A cable requirements
- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- IEC 61156-5:2020 (Ed. 3.0)
- EN 50173-1:2018 / EN 50173-2:2018
- EN 50288-10-1:2012
- TIA-568.2-E:2024

Standards for flammability, halogen acidity, and smoke performance
- IEC 60332-1-1:2015 (Ed. 1.1) / IEC 60332-1-2:2025 (Ed. 2.0)
- IEC 60754-2:2019 (Ed. 2.1)
- IEC 61034-1:2019 (Ed. 3.2) / IEC 61034-2:2019 (Ed. 3.2)

Technical report	EC Cabling product ID	CS valid until
12625236, DANAK-19/25815	7331	1 May 2027

This product has been tested by FORCE Technology and complies with the requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance schedule, which implies that FORCE Technology performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis.
This compliance statement has been revised, original issue date 7 May 2026.

Hørsholm, 19 May 2026

Nis Jepsen
Specialist, Project Manager

Lars Lindskov Pedersen
Senior Team Leader, Test Manager

FORCE Technology
Venlighedsvej 4
2970 Hørsholm
Denmark
Tel. +45 43 25 14 00
lan.forcetechnology.com