

Attestation of Conformity

No. 2019-475

Cables for use in construction works Reaction to fire class D_{ca}

Company

Mayflex Holdings Limited
Junction Six Industrial Park
Electric Avenue
Birmingham, B6 7JJ
United Kingdom

Product description

Screened communication cable (U/FTP) with solid conductors
2×4 twisted pairs, LSZH jacket

Product identification

XeLan CAT6a U/FTP S/FOIL CABLE 2x500M
Part no. 1000-0194, 1000-0194-xxx (xxx: coding for length and colour)

Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 50399:2011 including amendment A1:2016
- EN 61034-2:2005 including amendment A1:2013
- EN 60754-2:2014
- EN 13501-6:2018

Reaction to fire classification

Class D_{ca}-s1a,d1,a1

Technical report


T930841-03, DANAK-19/20341

EC Cabling product ID

6954

This product has undergone a one-time test performed by FORCE Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

Hørsholm, 1 August 2019



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department