

Attestation of Conformity

No. 2022-113A

Cables for use in construction works Reaction to fire class D_{ca}

Company

Molex Connected Enterprise Solutions Sp. zo.o.
ul. Tczewska 2, Rokitki
83-112 Lubiszewo
Poland

Product description

Screened communication cable (U/FTP) with solid conductors
4 twisted pairs, LSZH

Product identification

CBL U/FTP C6A 4PR LS0H Dca-s1,d2,a1
Part no.: CAA-0322L-VI (0183020033) 500m reel

Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 50399:2011 including amendment A1:2016
- EN 60754-2:2014 including amendment A1:2020
- EN 13501-6:2018

Reaction to fire classification

Class D_{ca}-s1,d2,a1

Technical report

12222994-01, DANAK-19/22512


EC Cabling product ID

7312

This product has undergone a one-time test performed by FORCE Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

This Attestation of Conformity has been revised, original issue date 11 February 2022.

Hørsholm, 14 February 2022



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department