Compliance Statement

No. 2025-680

Screened Channel, Class E_A

Company
Multimedia Connect by Adaltra
ZAC des Hauts de Wissous
Air Park de Paris
Bâtiment de Cormoran
3 rue Jeanne Garnerin
91320 Wissous
France

Channel Identification (2 connector model)

Horizontal cable:
F5554SHx (x: coding for colour/packaging)

RJ45 connector for telecommunications outlet and patch panel:
BC6AFSTLx (x: coding for packaging)

Cords:
CORD6ASFxxMSH (xx: coding for length)

Generic cabling standards - Class E_A Channel requirements
- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-E:2024

Technical report	**EC Cabling product ID**	**CS valid until**
12531127-12, DANAK-19/25358	5480	1 February 2027

This product has been tested by FORCE Technology up and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 17 December 2025

Nis Jepsen
Specialist, Project Manager

Lars Lindskov Pedersen
Senior Team Leader, Test Manager

FORCE Technology
Venlighedsvej 4
2970 Hørsholm
Denmark
Tel. +45 43 25 14 00
lan.forcetechnology.com