Compliance Statement

No. 2025-691

Screened Permanent Link, Class E_A

Company
Multimedia Connect by Adaltra
ZAC des Hauts de Wissous
Air Park de Paris
Bâtiment de Cormoran
3 rue Jeanne Garnerin
91320 Wissous

Permanent Link Identification (2 connector model)

Horizontal cable:
5254SHx (x: coding for colour/packaging)

RJ45 connector for telecommunications outlet and patch panel:
LK6AFSTLx (x: coding for packaging)

Generic cabling standards - Class E_A Permanent Link requirements
- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-E:2024

Technical report	**EC Cabling product ID**	**CS valid until**
12431640-09, DANAK-19/24667	6702	1 February 2027

This product has been tested by FORCE Technology and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 17 December 2025

Nis Jepsen
Specialist, Project Manager

Lars Lindskov Pedersen
Senior Team Leader, Test Manager

FORCE Technology
Venlighedsvej 4
2970 Hørsholm
Denmark
Tel. +45 43 25 14 00
lan.forcetechnology.com