

Compliance Statement

No. 2021-020

Screened Channel, Class E_A

Company

Nexans Cabling Solutions
Alsembergsesteenweg 2, B3
1501 Buizingen
Belgium

Channel Identification (4 connector model)

Horizontal cable:

N100.69xG-yy-LANmark 6A/10G F/FTP Category 6A 500 MHz LSZH

RJ45 connector for telecommunications outlet, consolidation point:

N420.66A-LANmark-6A Snap-in Connector Cat 6A Screened for solid copper wire
N420.67A-LANmark 6A Snap-in Connector Cat 6A Screened for stranded copper wire

Terminal cord, patch cord, equipment cord:

N11A.U1F020yz-LANmark-6A Ultim Patch Cord Cat 6A Screened LSZH

Generic cabling standards - Class E_A Channel requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018

Technical report

12030631-02, DANAK-19/21638

EC Cabling product ID


5225

CS valid until

1 January 2022

This product has been tested by FORCE Technology up and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 18 January 2021



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department

