

Compliance Statement

No. 2021-561

Screened Channel, Class E_A

Company

Ningbo Handian Cable Co., Ltd.
East Guanhaiwei Industrial Zone
Cixi, Zhejiang 315314
China

Channel Identification (4 connector model)

Horizontal cable:

Screened HANDIAN S/FTP CAT6A LSZH
Part no. KEG-X6ABB

RJ45 connector for telecommunications outlet and consolidation point:

Screened CAT6A FTP TOOLLESS KEYSTONE JACK connector
Part no. KEG.6ABCM1

Terminal cord, patch cord, equipment cord:

Screened S/FTP CAT6A PATCH CORD
Part no. KEG.T6ABB-0500 LSZH GY
KEG.T6ABB-XXXX Y ZZ [XXXX-Meter, Y-Jacket(PVC No indication), ZZ-Color]

Consolidation point cord:

Screened Category 6A cord
Part no. KEG.T6ABB-0500 LSZH GY (with jack KEG.6ABCM1 added for CP)

Generic cabling standards - Class E_A Channel requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018

Technical report

12128534-02, DANAK-19/22114

EC Cabling product ID

7140

CS valid until

1 October 2022

This product has been tested by FORCE Technology up and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 16 August 2021



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department

