

Attestation of Conformity

No. 2020-543

Cables for use in construction works Reaction to fire class E_{ca}

Company

Ningbo Handian Cable Co., Ltd.
East Guanhaiwei Industrial Zone
Cixi, Zhejiang 315314
China

Product description

Screened communication cable with solid conductors,
one pair (2 conductors), LSZH jacket

Product identification

Alarm cable
Type: JE-H(st)H FE 180 E90 1x2x0.8

Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 13501-6:2018

Reaction to fire classification

Class E_{ca}

Technical report

12028785-01, DANAK-19/21288

EC Cabling product ID

7133

This product has undergone a one-time test performed by FORCE Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

Hørsholm, 17 July 2020



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department