

Compliance Statement

No. 2023-726

Screened Channel, Class E_A

Company

PAMix Cables Ltd
LIULIN 6, ULITSA 668
Sofia
Bulgaria

Channel Identification (4 connector model)

Horizontal cable:

PAMix CAT6A cable, Part no.: 10011xx

RJ45 connector for telecommunications outlet:

PAMix RJ45 Female Cat6A, Shielded, Part no.: 1005xxx

Terminal cord, patch cord, equipment cord:

PAMix CAT6A Patch Cord, Part no.: 101xxxx
Plug: PAMix CAT6A male screened Part no.: 1005401

Consolidation point cord, equipment cord:

PAMix CAT6A Patch Cord Part no.: 101xxxx
(with PAMix CAT6A Keystone Jack added)

Including use with:

Wall Outlet: PAMix CAT6A Wall Outlet Part no. 10059xx
Patch Panel: PAMix CAT6A Patch panel Part no. 10050xx

Generic cabling standards - Class E_A Channel requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018

Technical report

12334762, DANAK-19/23864

EC Cabling product ID


7261

CS valid until

1 July 2024

This product has been tested by FORCE Technology up and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 30 November 2023



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department

