

Compliance Statement

No. 2023-332

Screened Channel, Class E

Company

PCnet Wire & Cable Co., Ltd.
No. 381, Sec 1, Jhongping road
Hukou Township
Hsinchu County 30341
Taiwan (R.O.C.)

Channel Identification (4 connector model)

Horizontal cable:

PCnet CAT.6 66704 Screened Cable

RJ45 connector for telecommunications outlet, consolidation point, and patch panel:

6KTxxx CAT.6 Screened Keystone Jack

Terminal cord, patch cord, consolidation point cord, and equipment cord:

962xxx CAT.6 Screened patch cord (with jack 6KTxxx added for CP and equipment cord)

Patch panel (mounting fixture):

6PHxxx CAT.6 Patch Panel

Generic cabling standards - Class E Channel requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018

Technical report

12233528-01, DANAK-19/23456

EC Cabling product ID


5853

CS valid until

1 March 2024

This product has been tested by FORCE Technology up and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 24 May 2023



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department