

# Compliance Statement

No. 2023-333

## Screened Channel, Class E<sub>A</sub>

### Company

PCnet Wire & Cable Co., Ltd.  
No. 381, Sec 1 Jhongping RD  
Hukou Township  
Hsinchu County, 30341  
Taiwan (R.O.C)

### Channel Identification (4 connector model)

#### Horizontal cable:

PCnet Data Connx 10G Category 6A BULK Cable

#### RJ45 connector for telecommunications outlet, consolidation point, and patch panel:

PCnet Data Connx 10G Keystone Jack

#### Terminal cord, patch cord, consolidation point cord, and equipment cord:

PCnet Data Connx 10G Category 6A Patch Cord (with jack added for CP and equipment cord)

#### Patch panel (mounting fixture):

PCnet Data Connx 10G 24 Port Patch Panel

### Generic cabling standards - Class E<sub>A</sub> Channel requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018

### Technical report

12233528-02, DANAK-19/23457

### EC Cabling product ID


5007

### CS valid until

1 March 2024

This product has been tested by FORCE Technology up and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 24 May 2023



Lars Lindskov Pedersen  
Test Manager



Dennis Andersen  
Head of Department