

Attestation of Conformity

No. 2019-787

Cables for use in construction works Reaction to fire class D_{ca}

Company

PCnet Wire & Cable Co., Ltd.
No. 381, Sec. 1, Jhongping Rd.
Hukou Township
Hsinchu County 30341
Taiwan (R.O.C.)

Product description

Unscreened communication cable (U/UTP) cable with solid conductors
4 twisted pairs, LSZH

Product identification

PCnet SupremeNet 250 66504H-Dca CAT.6 U-UTP LSZH
Part no.: 66504142xx-2(G) (xx: jacket colour)

Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 50399:2011 including amendment A1:2016
- EN 60754-2:2014
- EN 13501-6:2018

Reaction to fire classification

Class D_{ca}-s2,d2,a1

Technical report


T836567-13, DANAK-19/20719

EC Cabling product ID

7016

This product has undergone a one-time test performed by FORCE Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

Hørsholm, 27 November 2019



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department