

Compliance Statement

No. 2021-049

Data communication cable, Category 6A

Company

QPCOM Inc.
6030 NW 99 Ave. Suite 404
Miami, FL 33178
USA

Product description

Screened cable (U/FTP) characterised up to 500 MHz
Horizontal floor wiring cable, 100 Ω
4 individually foil screened twisted pairs
Flame retardant, halogen free

Product identification

QP-66304AFL CAT 6A U/FTP LSZH

Generic cabling and cabling components standards - Category 6A cable requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- IEC 61156-5:2020 (Ed. 3.0)
- EN 50173-1:2018 / EN 50173-2:2018
- EN 50288-10-1:2012
- TIA-568.2-D:2018

Standards for flammability, halogen acidity, and smoke performance

- IEC 60332-1-1:2015 (Ed. 1.1) / IEC 60332-1-2:2015 (Ed. 1.1)
- IEC 60754-2:2019 (Ed. 2.1)
- IEC 61034-1:2019 (Ed. 3.2) / IEC 61034-2:2019 (Ed. 3.2)

Technical report

12122205-02, DANAK-19/21695

EC Cabling product ID


5810

CS valid until

1 February 2022

This product has been tested by FORCE Technology and complies with the requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance schedule, which implies that FORCE Technology performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis.

Hørsholm, 26 January 2021


Lars Lindskov Pedersen
Test Manager


Dennis Andersen
Head of Department