

Attestation of Conformity

No. 2022-792

Cables for use in construction works Reaction to fire class D_{ca}

Company

Qubix S.p.A.
Via Canada 22/A
35127 Padova
Italy

Product description

Unscreened communication cable (U/UTP) with solid conductors,
4 twisted pairs, LSZH

Product identification

Cavo R6UT4H24 C6 U/UTP AWG24 LSZH Dca
Part no. M05D2701

Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 50399:2011 including amendment A1:2016
- EN 60754-2:2014 including amendment A1:2020
- EN 13501-6:2018

Reaction to fire classification

Class D_{ca}-s2,d2,a1

Technical report


12234170-01, DANAK-19/23122

EC Cabling product ID

7442

This product has undergone a one-time test performed by FORCE Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

Hørsholm, 14 December 2022



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department