Attestation of Conformity

No. 2024-455

Cables for use in construction works
Reaction to fire class D_{ca}

Company
Securi-Flex Ltd
Unit 6-10 Mackley Industrial Estate
Henfield Road
Small Dole, BN5 9XR
United Kingdom

Product description
Screened communication cable (F/UTP) with solid conductors, 4 twisted pairs, LSZH

Product identification
Category 6, 4pr FTP LSZH CPR:Dca -s2 -a1 -d2
Part no. SFX/C6-FTP-LSZH-D-xxx (xxx=colour)

Reaction to fire standards
- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 50399:2022
- EN 60754-2:2014 including amendment A1:2020
- EN 13501-6:2018 including amendment A1:2022

Reaction to fire classification
Class D_{ca}-s2,d2,a1

Technical report
12427647-10, DANAK-19/24355

EC Cabling product ID
7655

This product has undergone a one-time test performed by FORCE Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

Hørsholm, 12 July 2024

Lars Lindskov Pedersen
Test Manager

Dennis Andersen
Head of Department

FORCE Technology
Venlighedsvej 4
2970 Hørsholm
Denmark
Tel. +45 43 25 14 00
lan.forcetechnology.com