

Attestation of Conformity

No. 2020-251

Cables for use in construction works Reaction to fire class D_{ca}

Company

SKG Netzwerktechnik GmbH
Himberger Strasse 50
A-2320 Schwechat
Austria

Product description

Screened communication cable (S/FTP) with solid conductors
4 twisted pairs, LSZH jacket

Product identification

SK10G Line CAT7 S/FTP 4P AWG23 LSOH
Part no.: CW047C23H3SK10G

Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 50399:2011 including amendment A1:2016
- EN 60754-2:2014
- EN 13501-6:2018

Reaction to fire classification

Class D_{ca}-s2,d2,a1

Technical report


12023855-01, DANAK-19/21017

EC Cabling product ID

7076

This product has undergone a one-time test performed by FORCE Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

Hørsholm, 10 March 2020



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department