

Compliance Statement

No. 2026-722A

Screened Permanent Link, Class E_A

Company

SOCAMONT Industries
ZI des Touches
9 rue des frères Lumière
53000 LAVAL
France

Permanent Link Identification (3 connector model)

Horizontal cable and Consolidation Point cable:

SOCAMONT Câble Cat6A FFTP LS0H 4 Paires 10 GBit 100ohms AWG23 - PN:6710, 6810
SOCAMONT Câble Cat6A FFTP LS0H 2x4 Paires 10 GBit 100 ohms AWG23 - PN:6711, 6814

RJ45 connector for Telecommunications Outlet, Consolidation Point, and patch panel:

SOCAMONT Jack COCCINELLE RJ45 Cat6_A FTP 10GIGA - PN:71009

Including use with:

Wall Outlet: SOCAMONT Plastron 1 entrée inclinée DIM 45 X 45 une entrée - PN:71227
Patch Panel: SOCAMONT Panneau non équipé 24 ports FTP à accroche Keystone 1U - PN:71007

Generic cabling standards - Class E_A Permanent Link requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-E:2024

Technical report

12623777-02, DANAK-19/25786

EC Cabling product ID

5370

CS valid until


1 June 2027

This product has been tested by FORCE Technology and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year. This compliance statement has been revised, original issue date 12 May 2026.

Hørsholm, 22 June 2026



Nis Jepsen
Specialist, Project Manager



Lars Lindskov Pedersen
Senior Team Leader, Test Manager

