

# Attestation of Conformity

No. 2020-084A

## Cables for use in construction works Reaction to fire class D<sub>ca</sub>

### Company

SUNF PU TECHNOLOGY (DONG-GUAN) CO., LTD.  
No. 261, Si-Li South Road  
Ta Ping Village, Tang Xia Town, Dong Guan  
Guangdong Province 523722  
China

### Product description

Screened communication cable (F/UTP) with solid conductors  
4 twisted pairs, LSZH

### Product identification

Sunf Pu cat6A Solid cable F/UTP LSZH  
Part no. SP-Cat.6A-07 Dca

### Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 50399:2011 including amendment A1:2016
- EN 61034-2:2005 including amendments A1:2013 and A2:2020
- EN 60754-2:2014 including amendment A1:2020
- EN 13501-6:2018

### Reaction to fire classification

Class D<sub>ca</sub>-s1a,d1,a1

### Technical report

T930665-09, DANAK-19/20785


### EC Cabling product ID

7056

This product has undergone a one-time test performed by FORCE Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

This Attestation of Conformity has been revised, original issue date 24 January 2020.

Hørsholm, 8 March 2021



Lars Lindskov Pedersen  
Test Manager



Dennis Andersen  
Head of Department