

Attestation of Conformity

No. 2020-085A

Cables for use in construction works Reaction to fire class D_{ca}

Company

SUNF PU TECHNOLOGY (DONG-GUAN) CO., LTD.
No. 261, Si-Li South Road
Ta Ping Village, Tang Xia Town, Dong Guan
Guangdong Province 523722
China

Product description

Screened communication cable (F/UTP) with solid conductors
4 twisted pairs, LSZH

Product identification

Sunf Pu cat6 Solid cable F/UTP LSZH
Part no. SP-Cat.6-08 Dca

Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 50399:2011 including amendment A1:2016
- EN 61034-2:2005 including amendments A1:2013 and A2:2020
- EN 60754-2:2014 including amendment A1:2020
- EN 13501-6:2018

Reaction to fire classification

Class D_{ca}-s1a,d1,a1

Technical report

T930665-09, DANAK-19/20785


EC Cabling product ID

7057

This product has undergone a one-time test performed by FORCE Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

This Attestation of Conformity has been revised, original issue date 24 January 2020.

Hørsholm, 8 March 2021



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department