

Attestation of Conformity

No. 2020-286

Cables for use in construction works Reaction to fire class E_{ca}

Company

SUNF PU TECHNOLOGY (DONG-GUAN) CO., LTD.
No. 261, Si-Li South Road
Ta Ping Village, Tang Xia Town, Dong Guan
Guangdong Province 523722
China

Product description

Unscreened communication cable (U/UTP) with solid conductors,
4 twisted pairs, LSZH

Product identification

Sunf Pu cat6 Solid cable U/UTP

Part number: SP-cat.6-02

Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendments A1:2015 and A11:2016
- EN 13501-6:2018

Reaction to fire classification

Class E_{ca}

Technical report


12024945-03, DANAK-19/21058

EC Cabling product ID

6908

This product has undergone a one-time test performed by FORCE Technology and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR) under AVCP system 3.

Hørsholm, 27 March 2020



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department