

Compliance Statement

No. 2021-668

Data communication cable, Category 6A

Company

Superior Technologies & Services DMCC
Unit 905, Fortune Tower, Cluster C
Jumeirah Lakes Towers
P.O. Box 309084
Dubai
UAE

Product description

Screened cable (F/FTP) characterised up to 500 MHz
Horizontal floor wiring cable, 100 Ω
2x4 individually foil screened twisted pairs with overall foil screen
Flame retardant, halogen free

Product identification

F/FTP CAT6A 4P 23AWG LSZH
CL004C6AF/FTP-LS

Generic cabling and cabling components standards - Category 6A cable requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- IEC 61156-5:2020 (Ed. 3.0)
- EN 50173-1:2018 / EN 50173-2:2018
- EN 50288-10-1:2012
- TIA-568.2-D:2018

Standards for flammability, halogen acidity, and smoke performance

- IEC 60332-1-1:2015 (Ed. 1.1) / IEC 60332-1-2:2015 (Ed. 1.1)
- IEC 60754-2:2019 (Ed. 2.1)
- IEC 61034-1:2019 (Ed. 3.2) / IEC 61034-2:2019 (Ed. 3.2)

Technical report

12132227-01, DANAK-19/22220

EC Cabling product ID


6736

CS valid until

1 October 2022

This product has been tested by FORCE Technology and complies with the requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance schedule, which implies that FORCE Technology performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis.

Hørsholm, 1 October 2021


Lars Lindskov Pedersen
Test Manager


Dennis Andersen
Head of Department

