

# Compliance Statement

No. 2024-174

## Unscreened Channel, Class E

### Company

TELECOCABLE  
C/Principe de Vergara, 71  
28006 Madrid  
Spain

### Channel Identification (3 connector model)

#### Horizontal cable:

CABLE UTP 4 PARES CATEGORIA 6 LSZH RIGIDO BLANCO, Ref. T4P6RL1

#### RJ45 connector for telecommunications outlet and patch panel:

TOMA 180° RJ45 CAT6 UTP, Ref. T001133.0005.001

#### Terminal cord, patch cord:

LAT.UTP LSHF CAT6 xM GR.568B, Ref. T241241.00x0.B01 (x: length)

#### Equipment cord:

PUNTO DE CONSOLIDACION UTP CAT.6 3 METROS, Ref. T0005241.0030.B01

### Generic cabling standards – Class E Channel requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018

### Technical report

12332445-02, DANAK-19/24071

### EC Cabling product ID

5849

### CS valid until

1 March 2025

This product has been tested by FORCE Technology up and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 12 February 2024



Lars Lindskov Pedersen  
Test Manager



Dennis Andersen  
Head of Department

