

# Compliance Statement

No. 2023-090

## Screened Channel, Class E<sub>A</sub>

### Company

TELECOCABLE  
C/Principe de Vergara, 71  
28006 Madrid  
Spain

### Channel Identification (3 connector model)

#### Horizontal cable:

CABLE S/FTP 4 PARES CATEGORIA 7 LSZH RIGIDO BLANCO, Ref. T4P7RL1

#### RJ45 connector for telecommunications outlet and patch panel:

TOMA 180° RJ45 CAT6A FTP, Ref. T001133.0009.001

#### Terminal cord, patch cord:

LAT.S/FTP LSHF CAT6A xM GR.568B, Ref. T251251.00x0.B01 (x: length)

#### Equipment cord:

PUNTO DE CONSOLIDACION S/FTP CAT.6A 3 METROS, Ref. T0009251.0030.B01

#### Generic cabling standards - Class E<sub>A</sub> Channel requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018
- 

#### Technical report

12232246-03, DANAK-19/23184

#### EC Cabling product ID


5850

#### CS valid until

1 March 2024

This product has been tested by FORCE Technology up and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 1 February 2023



Lars Lindskov Pedersen  
Test Manager



Dennis Andersen  
Head of Department

