

Compliance Statement

No. 2020-857

Screened Channel, Class E_A

Company

Vericom Global Solutions
10025 Investment Drive, Suite 120
Knoxville, TN 37932
United States

Channel Identification (4 connector model)

Horizontal cable:

SP6673X-GY0305MD

RJ45 connector for telecommunications outlet, consolidation point, and patch panel:

KJ680X

Terminal cord, patch cord, equipment cord:

RC680XXXX-XBL (XXXX denotes length)

Consolidation point cord, equipment cord:

SP6673X-GY0305MD (with jack and plug added)

Patch Panel:

PP680X-24

Generic cabling standards - Class E_A Channel requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018

including all channel alien crosstalk parameters (PS ANEXT and PS AACR-F)

Technical report

12036692, DANAK-19/21622

EC Cabling product ID


7030

CS valid until

1 January 2022

This product has been tested by FORCE Technology up and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 22 December 2020



Lars Lindskov Pedersen
Test Manager



Dennis Andersen
Head of Department