

# Compliance Statement

No. 2021-444

## Screened Channel, Class E<sub>A</sub>

### Company

Vivanco GmbH  
Ewige Weide 15  
22926 Ahrensburg  
Germany

### Channel Identification (4 connector model)

#### Horizontal cable:

VPCASFA4XXY3

#### Cords:

VPCCSFARXXYZ

#### Wall Outlet:

VPCJSNFAS

#### Patch Panel:

VPCPSFA241

### Generic cabling standards - Class E<sub>A</sub> Channel requirements

- ISO/IEC 11801-1:2017 (Ed. 1.0) / ISO/IEC 11801-2:2017 (Ed. 1.0)
- EN 50173-1:2018 / EN 50173-2:2018
- TIA-568.2-D:2018

including all channel alien crosstalk parameters (PS ANEXT and PS AACR-F)

### Technical report

12129057, DANAK-19/22033

### EC Cabling product ID


5879

### CS valid until

1 July 2022

This product has been tested by FORCE Technology up and complies with the electrical requirements of the above specified standards and "Terms and conditions for the EC VERIFIED programme for Generic and Coaxial Cabling", DQP231006. The product takes part in a maintenance of certification schedule, which implies that FORCE Technology performs a sample test of the product once a year.

Hørsholm, 29 June 2021



Lars Lindskov Pedersen  
Test Manager



Dennis Andersen  
Head of Department